

EnergySmart Pumping for Energy Savings

Energy Management and Operational Modeling

A poster by IDModeling in conjunction with Indio Water Authority

IDModeling
ENGINEERING INNOVATION


Indio Water Authority
Your Water: Our Responsibility.

The Challenge:

"If we sit here and do nothing, it's going to be expensive"

- Indio Water Authority

A Desert Utility's Challenge to Sustainable Closed System Operations




- Unstable system—VFDs “fight” each other
- Unique diurnal pattern with hourly irrigation peaks
- High energy costs

The Solution: Develop an operation plan to optimize pumping and lower energy costs.


Indio Water Authority Pump Operational Plan									
Facility Type	Low Demand			Transitions Low and High Demand			High Demand		
	VFD State	Control	Solid State	VFD State	Control	Solid State	VFD State	Control	Solid State
Plant 1	Booster Pump 1	X	X	X	X	X	X	X	X
Plant 2	Booster Pump 1	X	X	X	X	X	X	X	X
Plant 2	Booster Pump 2	X	X	X	X	X	X	X	X
Plant 3	Booster Pump 1	X	X	X	X	X	X	X	X
Plant 3	Booster Pump 2	X	X	X	X	X	X	X	X
Plant 4	Booster Pump 1	X	X	X	X	X	X	X	X
Plant 4	Booster Pump 3	X	X	X	X	X	X	X	X
Plant 4	Booster Pump 4	X	X	X	X	X	X	X	X
Wells	Well U	X	X	X	X	X	X	X	X
Well W	X	X	X	X	X	X	X	X	X

The Process:

1. Hydraulic Model Calibration



2. Energy Model Calibration



3. Calibration Cost Comparison

Total System Daily Cost: \$5,559.40
Projected Over August --> **\$172,341.40**

Actual Energy Billings: **\$165,647.53**
Percent Difference: **4.0%**

Total System Daily Cost: \$3,234.70
Projected Over February --: **\$90,571.60**


Actual Energy Billings: **\$89,397.00**
Percent Difference: **1.3%**

6. Cost and Energy Savings

	2010 Production (Cf)	2010 Production (MG)	2010 Average (MGD)	2010 Monthly Cost	Demand Condition	\$/MG (lowest Alt)	Projected Cost	Cost Savings
January	597757	447	14.4	\$93,801	Low	\$197	\$88,083	6.1%
February	506771	379	14.0	\$104,484	Low	\$197	\$74,676	28.5%
March	578868	433	14.4	\$109,202	Low	\$197	\$85,300	21.9%
April	871258	852	19.7	\$129,127	Transition	\$210	\$136,857	-6.0%
May	783941	888	21.0	\$135,857	Transition	\$210	\$113,456	9.8%
June	968663	725	24.2	\$160,615	High	\$200	\$144,912	9.8%
July	1123066	840	26.3	\$187,383	High	\$200	\$168,011	10.3%
August	1057989	751	27.3	\$163,308	High	\$200	\$158,375	1.3%
September	1023336	735	22.7	\$174,603	High	\$200	\$154,236	1.3%
October	674066	504	18.0	\$145,687	Transition	\$210	\$105,887	26.6%
November	681058	509	18.1	\$151,735	Transition	\$210	\$106,973	28.0%
December	554439	415	15.4	\$134,896	Low	\$197	\$81,700	39.4%
Overall				\$1,699,752			\$1,428,670	15.9%

- April billing data contained some errant readings; Actual savings may be higher.
- Save over \$250,000 per year on Energy;
- A nearly 16% savings!!!

5. Operational Alternative Comparison



Pump Operations Alternative Summary									
Daily Production (MG)	Daily Energy Cost (\$)	Cost per MG (\$/MG)	Percent of Collection	Percent of Inservice	Optimal Range (PSI)	Acceptable Range (PSI)	No. of VFDs Operating	No. of Plant VFD Pumps	No. of Plant VFD Pumps
13.1	\$3,286	\$2,722	\$2,885	\$4,241	\$3,811	\$3,729	\$5,589	\$5,701	\$5,449
\$247	\$226	\$208	\$197	\$218	\$214	\$210	\$231	\$209	\$200
100%	91%	84%	80%	N/A	N/A	N/A	100%	91%	87%
35%	99%	98%	100%	100%	95%	99%	99%	99%	97%
3	2	3	4	2	3	5	7	3	3
2	0	0	2	0	0	4	4	0	0
1	1	1	1	1	1	1	1	1	1
0	0	1	0	0	1	1	2	2	2
1	1	1	1	1	1	1	1	1	2
1	0	1	1	0	1	1	1	2	2

4. Operational Alternative Development

- Pressure Criteria:
 - 40-120 psi min/max acceptable operating range
 - Preferred (optimal) operating range 65-80 psi
- Pump Criteria:
 - Use most efficient pump
 - Well Pumps “on” for > 6 hours
 - Minimize # of VFDs at any one time
- VFD Criteria:
 - Minimize VFDs
 - Use Plant VFDs foremost
- Plant Criteria:
 - Plants operate at firm capacity