

This presentation premiered at WaterSmart Innovations

watersmartinnovations.com



Village of Cloudcroft, NM

PURewater Project

Eddie Livingston, P.E.

Livingston Associates, P.C.

Consulting Engineers

Water Smart Innovations '08

October 10, 2008

Wastewater Reuse

- Treated wastewater is a commodity....
Don't throw it away!
- It is a water resource that is a known quantity, already have rights, renewable supply.... Only requires treatment
- Various uses: irrigation of green spaces, traded for potable, augment SW/GW
- Ultimate in water conservation



What is Potable Reuse ?

- Using treated wastewater to augment a potable water supply
 - Planned Indirect Potable Reuse
 - Unplanned Indirect Potable Reuse
 - Direct Potable Reuse = Toilet to Tap (Pipe-to-Pipe)



Unplanned Indirect Reuse

- Occurs anywhere wastewater effluent is discharged into a surface water body (lake or river) that is used for drinking water supply by a downstream user
- Mississippi, Colorado, Rio Grande, etc.
- Drinking water receives “standard” treatment



Planned Direct Reuse

- Pipe-to-Pipe... from wastewater plant to drinking water system
- Not allowed by USEPA
- Windhoek, Namibia South Africa - since 1968 as supplement to reservoir supply, now 24,000 m³/day (100%)



Planned Indirect Potable Reuse (NRC)

- "... the abstraction, treatment and distribution of water for drinking from a natural source water that is fed in part by the discharge of wastewater effluent... The water receives additional treatment prior to distribution... In contrast, with direct potable reuse, the water is reused with no intervening environmental buffer," Issues in Potable Reuse, NRC, 1998 (p. 20, 21)



Planned Indirect Potable Reuse (EPA)

- "... the augmentation of a community's raw water supply with treated wastewater followed by an environmental buffer. The treated wastewater is mixed with surface and/or groundwater and the mix typically receives additional treatment before entering the water distribution system." Guidelines for Water Reuse, USEPA 2004, Ch. 2.6, p. 41



Indirect Potable Reuse

- Water Factory 21, California - 1976 treat 15 mgd for aquifer recharge
- Los Angeles County - 45 mgd for GW recharge (33% of total recharge)
- El Paso, Tx. - 1985 recharge Hueco
- North Texas Municipal Water District (Dallas) - 1987 24 mgd into watershed of the water supply reservoir



Indirect Potable Reuse

- Clayton Co. Ga., - 15 mgd to forest, river watershed supplying Atlanta
- Water Campus, Scottsdale Az. - 1998 recharges aquifer 10 mgd
- Singapore - 2003 NEWater Project supplies 4.3 million residents



Large IPR Projects

- Miami-Dade County, Florida is planning a \$1.1-billion indirect potable reuse project, with an ultimate capacity of 100-million gallons per day. The proposed treatment process includes microfiltration, reverse osmosis, advanced oxidation and UV disinfection (the treatment process is almost identical to that proposed by Cloudcroft).
- The City of Aurora, Colorado is planning a \$754-million indirect potable reuse project (the Prairie Waters Project), which will treat South Platte River water diverted downstream from the Denver Metro Wastewater Reclamation Plant. The project will provide 20 percent of Aurora's water supply, and will use filtration, activated carbon and UV disinfection.



Large IPR Projects

- The \$487-million Groundwater Replenishment (GWR) System in Orange County, California is designed to ultimately reuse approximately 140,000 acre-feet per year of advanced treated wastewater. The treatment process consists of microfiltration, reverse osmosis and UV-oxidation.



EPA Guidelines

- “For many cities or regions, the growing demand for water, lack of new water resources, and frequent calls for water conservation in low and consecutive low rainfall years have resulted in the need to augment potable supplies with reclaimed water. Indeed, in some situations, indirect potable reuse may be the next best alternative to make beneficial use of the resource.” (p. 43, emphasis added).



Water Environment Federation Statement of Support for IPR

- "...WEF supports the consideration and use of highly treated reclaimed water for indirect potable reuse...Indirect potable reuse is the introduction of highly treated reclaimed water to a surface water or groundwater system that is ultimately used as a potable water supply. Current engineering practice can provide treatment systems that are capable of reliably eliminating pathogens and reducing organic and inorganic contaminant concentrations to very low levels in reclaimed water. Therefore, local authorities should consider indirect potable reuse of reclaimed water as part of an integrated water resources management strategy." (10/2/98, emphasis added).



EPA Guidelines

- “On the basis of available information, there is no indication that health risks from using highly treated reclaimed water for potable purposes are greater than those from using existing water supplies (National Research Council, 1994).” (p. 104, emphasis added).

Cloudcroft, NM

- Population 750 permanent
- Swells to >2,000 weekends/holidays
- Avg. Demand 180,000 gpd
- Peak Demand 360,000 gpd
- Mountain community elev. 8600 ft.

Current Water Supply

- Water sources include springs and wells
- Drought has caused a reduction in spring flows and ground water levels
- More than 7 exploratory wells drilled
- Additional groundwater not available
- Conservation measures undertaken
- Water hauling during weekends



'PURe Water' Project Plan


- Augment potable water system with advanced treated wastewater
- Treat 100,000 GPD and blend up to 50/50 with natural spring/well water
- Treat blended mix again and place into distribution system
- Multi barrier treatment approach



'PURe Water' Treatment


- Membrane Bioreactor (MBR)
- Disinfection
- Reverse Osmosis (RO)
- Advanced Oxidation (UV/peroxide)
- Blending with Natural Waters
- Ultrafiltration (UF) and UV
- Activated Carbon (GAC)
- Disinfection





Water Quality

■ WW BOD/TSS	300/380 mg/L
■ WW TDS	650 mg/L
■ GW TDS	480 mg/L
■ SW TDS	330 mg/L
■ Distribution Exist TDS	400 mg/L
■ RO TDS	25 mg/L
■ New Blended TDS	250 mg/L




Membrane Bioreactor (MBR)

- Retrofit of existing wastewater treatment facility.
- Q_{avg} of 100,000 gpd.
- Pretreatment for reverse osmosis system.
- Disinfection with chloramines ($Cl_2 + NH_3$).

Constraint	Effluent Limit
BOD ₅	<5 mg/L
TSS	<5 mg/L
Total N	<10 mg/L
Turbidity	<1 NTU
SDI (15 min)	<3



Membrane Bioreactor



MBR-EQ Basin



LIVINGSTON ASSOCIATES, P.C.
Consulting Engineers



MBR Building



LIVINGSTON ASSOCIATES, P.C.
Consulting Engineers



MBR Building



LIVINGSTON ASSOCIATES, P.C.
Consulting Engineers



MBR Basin



LIVINGSTON ASSOCIATES, P.C.
Consulting Engineers





RO/UF Site



LIVINGSTON ASSOCIATES, P.C.
Consulting Engineers



RO/UF Building



LIVINGSTON ASSOCIATES, P.C.
Consulting Engineers



Reverse Osmosis (RO)

- Follows MBR treatment step.
- Utilize elevation difference for gravity feed to RO.
- Disinfection with UV and hydrogen peroxide.
- Removal of total dissolved solids (TDS) and emerging pollutants of concern (EPOCs).

Constraint	Operating Limit
TDS	<50 mg/L
Salt Rejection	99.20%
Min Permeate Recovery	80%
Max Feed Pressure	175 psi



RO System



LIVINGSTON ASSOCIATES, P.C.
Consulting Engineers



Rio Rancho IPR Pilot Study Conclusions

- “The RO permeates tested...all were lower than the SDWA and NMWQCC standards. A majority of the constituents tested were well below the standards and below laboratory detection limits. Two samples of raw influent, MBR permeate and RO permeate were analyzed for a group of emerging contaminants. Many of the compounds were removed through the activated sludge portion of the process, and all of the contaminants were removed to below detection limits by the RO process...” (*Water Reuse Program Pilot-Scale Evaluation for an Integrated Membrane System (IMS) Final Report, August 2005, MWH-Americas, Inc. in association with the University of New Mexico, p. ES-2, emphasis added*).

UV Oxidation

- Hydrogen peroxide dosed ahead of UV
- hydroxyl radicals break apart organics
- Reduction of EDC's, PPCP's, NDMA
- California DHS action level 1-log reduction of NDMA (10 ppt)
- Trojan UVPhox used for OCWD 70-MGD Groundwater Replenishment System



Environmental Buffer

- Natural water body that separates treated ww and intake to DW plant
- May be reservoir, river, lake, aquifer
- Opportunity for contaminant reduction (level of protection unknown)
- Lag-time from ww treatment to potable system (operator response time)
- Blending with natural waters



Where is your Buffer?


- Covered Reservoir Storage
- Provides 40-60 Days Detention
- RO treatment
- UV Ox treatment
- UF/UV treatment
- GAC treatment



Ultrafiltration (UF)

- Feed water from covered storage reservoir.
- Removal of solids, bacteria and viruses.
- Disinfection with sodium hypochlorite.
- Q_{avg} of 180,000 gpd.

Constraint	Operating Limit
Max Turbidity	0.3 NTU
Avg Turbidity	0.1 NTU
<i>Giardia/Crypto</i> Removal	>4-log
<i>Virus</i> Removal	>2-log
<i>Bacteria</i> Removal	>5-log
Min Filtrate Recovery	95%



Ultrafiltration (UF) System



LIVINGSTON ASSOCIATES, P.C.
Consulting Engineers



Activated Carbon

- Blended treated RO perm and natural waters, post UF and UV
- Polish UF filtrate
- Demonstrated removals of organics and certain PPCPs and EDCs

Concentrate Management

- Concentrate TDS approx. 2,000 mg/L
- Evaporation/Storage Pond
- Snow making (blended w/MBR perm)
- Irrigation of Ski Area (blended)
- Dust control/Construction/Gravel Wash
- Deep well injection
- Additional recovery/Others



Ski Area



LIVINGSTON ASSOCIATES, P.C.
Consulting Engineers



Aquifer Recharge

- Phase 3 Program
- Limited to Pumphouse Canyon
- Estimated 90-120 day detention
- May lose >50% (not captured)
- Considered secondary/alternate storage location (for excess flows, emergencies, reservoir maintenance)



Project Costs

■ Capital	\$3,500,000
■ Equipment O&M	\$0.80/1,000 gal
■ Operator/Misc.	\$50,000/yr
■ Cost of Water (O&M)	\$2.40/1,000 gal
■ Total Cost of Water	\$9.00/1,000 gal

NMED Approvals

- NMED Drinking Water Bureau approved
- Department supports indirect reuse and comfortable with technology, review included EPA SDWA LT2 (ESWTR)
- Village must ensure proper operators, system monitoring, alarming and shutdown procedures



Public Involvement

- Public Meetings
- Discussed in WW Master Plan
- Discussed in Comp Plan
- Village Council Meetings
- Business leaders understand need
- No negative comment from general population



Schedule

- MBR start-up early 2009
- RO/UF start-up spring 2009
- Certification/testing May/June 2009
- Introduce water into PWS July 2009



Questions?



LIVINGSTON ASSOCIATES, P.C.
Consulting Engineers

