Leak Detection, Conservation, and Customer Engagement **Using AMI/Smart System**

Jason Wen, PhD, PE Michael Santillan Derwin Dy, PE









City of Lakewood, California ALIFORNI City of Lakewood **Department of Water Resources Golden State** ALO VERD Water Company CENTRALIA CARSO

OFLAKA



- 3 water storage facilities (13 MG)
- 3 booster stations (15 pumps)
- 5 Emergency Interconnections

 $\Delta_{\mathbf{N}}$

- 180 miles of water mains (4" to 27")
- 20,300 meter service connections to ~60,000 population
- Demand 12 MGD or 11,000 GPM
- Annual Production 7,000 AF + 2,200 AF (Exported)




Smart Water System

- Smart Meters: AMI System 100% replacement (20,300)
- Pipeline Assessment: AI/ML to use historical leak data to predict when & where the future breaks would occur and prioritize pipeline replacement
- Active Leak Monitoring: Acoustic Sensors to monitor small breaks from deep transmission main
- Distribution Sensors Transient pressure monitoring
- Pump Control Optimization: Pressure and energy control platform to improve efficiency and extend useful life of infrastructures, and reduce pipeline breaks and leaks

City of Lakewood - Utility Billing System Workflow

Technology Platform



(WR) Water Resources (FA) Finance Administration

NEPTUNe^{'ıli'} 360


Endpoint Summary Review

7-Day Summary as of : 08/27/2020

4

4

Detail Report >>



4




Q CUSTOMER INQUIRY


BILLING SERVICES


UTILITY MANAGEMENT

REPORTS



Top 10 Accounts by Consumption

















Neptune AMI System

- Meter Readings: <2% re-read
- Gateway Status
- Continuous/Intermittent Consumption
- Reverse Flow

.

- Top consumption accounts
- Hourly live (1-day old) data
- Re-read by AMI system



City of Lakewood

Accounts

٥ŀ	SFR	19,237
•	Other	3,841
	Commercial	977

Sep 2, 2020

Sep 13, 2020 11:00 PM

Analytics

Consumption 375.9 MG in Period 2020-4		Leak Detection		Tier Consumption 3.2% of SFR accounts within Tie	r 1 in Period 2
Compared to previous period	25 %	Detected in the last year	17,893	Compared to previous period	•
Compared to one year ago	. 12 %	Leaks alerted in the last year	3,829	Compared to one year ago	•
TOTAL MG BY READING PERIOD		ENGAGEMENT WITH ALERTS		% ACCOUNTS WITHIN TIER 1	
III					

Clicked

Resolved

90,812

44%

Engagement

2019

2020

0

Mailings

Active Recipients STARTING SOON

Opened

Group Messenger

0 messages sent in past year

Messages delivered Open rate of emails

MESSAGE RECIPIENTS




Portal Visits 27,372 in past 90 days

Desktop visits	64%
Mobile visits	36%

ious period			
pared to year ago		•	9.6
COUNTS WITHIN TIER 1			
	2020		

pdates	1
ldresses	13
F OCCUPANTS	




Portal	Registrations

697 in past 90 days

Registered Accounts since program start	11,537
Total % among eligible accounts	48.0%

Porta Customer



water was used . Compare that to what was used the previous

click, pay your water and trash bill online. And, compare your current bill to your previous two

Notifications - Look here to get updated information about the City and water use information.

I Want To ... - Trouble shoot and check if you have a leak, sign up (this way no there's no need to water most and get advice how

Recommended - Look here to get general water conservation advice and turn those savings



Registered Accounts o

III SEE ALL

11,528

BREAKDOWN OF REGISTRANTS

Source of Registrants

Other 79%

Group Message 17% Leak Alert (automated) 2.9% Leak Alert (staff) 0.4% Conversation 0.3%

WaterScore of Registrants

Most Efficient 17%
Average Households 22%
High Users 33%
No WaterScore 28%

Tier of SFR Registrants


Tier 1 36%


Tier 2 64%

WaterSmart Portal

- Data Info knowledge Management tool
- Alert and remarkably reduce internal leaks
- Enhance customer involvement
- Hourly data provide more information
- More efficient customer services

Portal Registrations 697 in past 90 days		Portal Visits 27,372 in past 90 days	
Registered Accounts since program start	11,537	Desktop visits	64%
Total % among eligible accounts	48.0%	Mobile visits	36%






Total Open Leak Rate



accounts



Pipeline Condition Assessment (AI/ML by Fracta)




Transmission and	Distribution Mains	in the Water Mains					
	Pipe Length						
Туре	(ft)	96					
CI	353,758	37.31%					
AC	238,322	25.14%					
ST	6,124	0.65%					
DI	99,924	10.54%					
CCP	49,574	5.23%					
C900	200,379	21.14%					

Transmission and Distribution Mains in the Water Mains

Pipe Diameter		% of Total
(inches)	Length (ft)	Length
4	153,190	16.2%
6	204,846	21.6%
8	402,968	42.5%
10	40,110	4.2%
12	79,650	8.4%
14	3,597	0.4%
16	24,457	2.6%
18	3,354	0.4%
20	18,102	1.9%
24	1,850	0.2%
27	15,956	1.7%
Total	948,080	100.0%


Summary of Pipe Age by Pipe Size in Length (Feet)



Pipe Diameter	r								
(inches)	Before 1950	1950's	1960's	1970's	1980's	1990's	2000's	2010's	Unknown
4	5,782	146,122	0	1,286	0	0	0	0	0
6	9,035	117,862	5,427	38,015	12,588	21,864	0	0	54
8	11,397	143,689	3,037	6,079	2,265	62,553	126,699	42,158	5,091
10	1,324	36,426	166	679	0	1,515	0	0	0
12	4,133	43,667	1,202	3,525	0	11,206	1,842	0	14,075
14	0	3,551	0	46	0	0	0	0	0
16	1,286	16,450	0	4,520	0	0	0	0	2,201
18	0	2,896	0	0	0	0	0	0	458
20	0	17,358	0	427	0	0	316	0	0
24	0	1,634	0	215	0	0	0	0	0
27	2,605	10,792	0	0	0	2,559	0	0	0
Total	35,563	540,448	9,831	54,793	14,854	99,697	128,857	42,158	21,879
%	3.8%	57.0%	1.0%	5.8%	1.6%	10.5%	13.6%	4.4%	2.3%

Total
153,190
204,846
402,968
40,110
79,650
3,597
24,457
3,354
18,102
1,850
15,956
948,080
100.0%

Pipe Asset Summary by Install Year





Installation Year

- Cast Iron
- Steel
- Asbestos Cement


Х

- Ductile Iron
- PLAS
- Other
- CON





LOF Analysis by Fracta



Breaks vs. Pipe Materials



Breaks vs. Years




Active Monitoring

Echologics DS System

















Acoustic Sensors


- Pilot for major commercial area
- Distribution line in the pilot area is larger and deeper
- Identify minor leaks early and prevent disaster situation
- No surprise ... yet



Distribution Pressure Sensors (Mueller)




Distribution Pressure



Distribution Pressure


- Catch minor break earlier and respond main break faster
- Transient pressure observations
- Smooth system pressure to prevent breaks and leaks



Pump Control and Optimization

SCADA Improvement





FLANT 13				
PUMP	HP	GPM BOU		
1	40			
2	50	1000		
3	76	1600		
4	75	1500		

Overviews. Map Hydraulic Network Pump Control

Wells

Well 2A Well 4 Well 6 Well 8 Well 10 Well 13A Well 15 Well 17 Well 18 Well 22 Well 27

Plants

Plant 4

- Booster 8
- Plant 13
- Plant 22

Plant 27

Intigation

Bolivar

Alarms

Alarm Journal

Log in

guest

Mon 06/10/19 07:20:14

Central Pressure Control


<u>Command Alarm Overview Well Plant Trend Data Report Admin Doc Windows Help</u>

Pump Control

					Sequen	ce Control	
Pump	Flow Cap.	Status	Available	Control Mode	Delay After Start	Delay After Sto	p 24 Hour Trend
Booster 8	2000	On	Available	System	120	120	
Plant 04 P4	1700	On	Available	System	120	120	
Plant 13 P1	800	On	Available	System	120	120	
Plant 04 P6	1000	On	Available	System	120	120	
Well 18	660	Off	Unavailable	System	120	120	
L							
Well 02A	470	On	Available	System	120	120	
Plant 04 P3	1000	Off	Available	System	120	120	
Plant 04 P2	1000	Off	Available	System	120	120	
Plant 13 P2	1000	Off	Available	System	120	120	
	1000		manane	- System	120	120	
Plant 04 P7	1100	Off	Available	System	120	120	
Well 22	800	Off	Unavailable	System	720	120	
Well 22	000	UII	Ullavallable	System	120	120	
Plant 04 P5	2000	Off	Available	System	120	120	
		0.6		Quetarra			
Well 17	900	Off	Unavailable	System	120	120	
Well 04	550	Off	Unavailable	System	120	120	
		0.00					
Plant 13 P3	1500	Off	Unavailable	System	120	120	
Plant 13 P4	1500	Off	Unavailable	System	120	120	
Plant 22 P1	0	Off	Unavailable	Local	60	60	
Plant 22 P2	0	Off	Unavailable	Local	60	60	
Plant 22 P3	0	Off	Unavailable	Local	60	60	
Plant 22 P4	n	Off	Unavailable	Local	60	60	
	0	UI	CARGADIONIC	Local			

Pressure Selection						
Site	Pressure	Use				
Booster 8	56.3 psi	ON				
Well 02A	53.0 psi	OFF				
Well 04	56.5 psi	OFF				
Well 17	54.6 psi	OFF				
Well 18	51.7 psi	OFF				
Well 22	57.0 psi	OFF				
Plant 04 N	58.4 psi	OFF				
Plant 04 S	60.9 psi	OFF				
Plant 13	56.6 psi	OFF				

Change	Sequence
Stage	e Control
Stage Pump	
Stage Timer	0 sec
Stop Pressure	62.0 psi
Start Pressure	52.0 psi
Pressure	Demand
56.2 _{psi}	5891 gpm
Started Plant (D4 P3 07:58



Overviews

<u>Map</u> <u>Hydraulic</u> <u>Network</u> <u>Pump Control</u>

Wells

Well 2A Well 4 Well 6 Well 8 Well 10 Well 13A Well 15 Well 17 Well 18 Well 22 Well 27

Plants


Plant 4 Booster 8 Plant 13 Plant 22 Plant 27


Irrigation


<u>Bolivar</u>

<u>Alarms</u> Alarm Journal

<u>Log In</u>









Central Pressure Control

- Ease of arranging well and pump sequence by matching the demand at various levels
- Better utilizing VFD pumps
- Smooth pressure peaks and reduce leaks
- Preschedule pump sequences to save energy
- Pressure control to reduce leaks and enhance conservation
- Utilize demand data from AMI to schedule the supply configuration and capital project








AWWA Free Water Audit Software: Water Balance

Water Audit Report for: CITY OF LAKEWOOD (1910239)						
			2019	1/2019 - 12/2019		
			Data Validity Score:	80		
		Water Exported 3,245.430			Billed Water Exported	
				Billed Authorized Consumption	Billed Metered Consumption (wa exported is removed)	
Own Sources (Adjusted for			Authorized Consumption	6,459.340	Billed Unmetered Consumption	
known errors)			6,468.420	Unbilled Authorized Consumption	Unbilled Metered Consumption	
9,852.290				9.080	Unbilled Unmetered Consumptio	
	System Input 9,852.290	Water Supplied		Apparent Losses	Unauthorized Consumption	
		6,606.860		48.854	Customer Metering Inaccuracies	
			Water Losses		Systematic Data Handling Errors	
Water Imported 0.000			138.440	Real Losses 89.586	Leakage on Transmission and/or Distribution Mains Not broken down	
					Leakage and Overflows at Utility Tanks <i>Not broken down</i>	
					Leakage on Service Connection Not broken down	



- Significantly enhance customer services and relations
 - Maximizing reading success rate and billing accuracy
 - Identify and alert potential customer-side leaks
 - Proactive customer communication and issue resolution
 - Provide tools to utility staff to better assist customers
 - Improving communication and responsiveness to customers
- Use more technology being more efficient and cost-effective
 - Automation to manage increasing labor cost
 - Revenue recovery and control water loss
 - Increase data availability/accuracy to improve reporting
 - Optimize future CIP investment
 - TOU rate possible to reflect cost of services
- Integration and visualization of technology platforms to be smarter
 - Identify and visualize issues timely from on-going platforms
 - Improve understanding of system operations
 - Reduce breaks and leaks through pressure management
 - Smooth pressure variation to extend pipeline life
 - Data-driven management for annual CIP budget\$!

Summary





Thank You!

Jason Wen jwen@lakewoodcity.org

QUESTIONS?



